

# PRESSURE MANAGEMENT AS A PART OF WATER DEMAND MANAGEMENT IN DRAKENSTEIN MUNICIPALITY

Presented by **André Kowalewski**

Engineer: Water Services

13 July 2012

# Introduction

- Between the years of 1989 and 1999 Drakenstein Municipality experienced an average water demand growth of 3.5% per annum
- Non Revenue Water was unacceptably high - In excess of 33% (@ 1999)
- Static Pressure in the low laying areas were also unacceptably high [in excess of 9 bar (900kPa)]
- The total AADD of Paarl, which accounts for about 55% of the total population of Drakenstein Municipality, was in the vicinity of 17.9Mm<sup>3</sup>/annum (17 900 000 000 litres)



# Introduction (cont.)

- Goals of the Water Demand Management Scheme
  - ✓ Reduce the high percentage of non revenue water
  - ✓ Reduce the high static pressures
  - ✓ Reduce the high AADD value
  - ✓ To improve the total revenue collected by the Municipality
  - ✓ To provide a constant and efficient service to the consumer
  - ✓ To conserve water, which became a very scarce commodity

# Methodology



# Methodology (cont.)

- Total Population = 224 240
  - Paarl = 138 650
- Annual Water Demand - Paarl:
  - Prior Implementation of WDMS = 17 900MI per annum
  - Post Implementation of WDMS = 11 500 MI per annum
- Demand per capita = 250 litres/person/day
- Drakenstein Water Sources
  - Paarl Mountain (10%)
  - City of Cape Town (90%)



# Methodology (cont.)

- Project Methodology and Design
  - Hydraulic modelling of master plan for reticulation network
  - Rising block tariff structure
  - Increased public awareness
  - Metering of all unmetered water metres
  - Promotion of water saving devices
  - Refurbishment/Replacement of network infrastructure
  - Leak Detection /Repair
- **Pressure Management**



# Methodology (cont.)

- **Pressure Management**
  - Water network consists of four pressure zones namely Main Road pressure zone, Central pressure zone, Leliefontein pressure zone and Denneburg pressure zone
  - The water network consists of 7 pressure reducing valves ranging from 100mm Ø to 300mm Ø with electronic controllers
  - Flow Modulation (Auto-watt & Modulo), Time Modulation (Auto-Watt & Modulo) and Loop Control (Regulo/Cello)
  - Various monitored pressure loggers at critical points
  - Controlling pressures during different times of the day, keeping lowest pressure at night when demands are lowest
  - Cost of implementation of pressure management system R2.6 Million (only during 2000/2001)




# Results

	Denneburg Pressure Zone	Klein Drakenstein Pressure Zone	Van der Stel Pressure Zone
Average Inlet Pressure	6.10 Bar	6.80 Bar	8.50 Bar
Average Outlet Pressure during Low Demand Periods	3.30 Bar	2.60 Bar	3.60 Bar
Decrease in Inlet pressure During Low Demand Periods	45.90%	61.80%	57.40%
Average Outlet Pressure during High Demand Periods	4.50 Bar	3.70 Bar	4.70 Bar
Decrease Inlet pressure During High Demand Periods	26.20%	45.60%	44.70%
Average Pressure at Critical Point During Low Demand Periods (Summer)	3.05 Bar	5.84 Bar	2.31 Bar
Average Pressure at Critical Point During High Demand Periods (Summer)	4.25 Bar	7.02 Bar	1.8 Bar
Average Pressure at Critical Point During Low Demand Periods (Winter)	3.15 Bar	6.2 Bar	3.64 Bar
Average Pressure at Critical Point During High Demand Periods (Winter)	4.31 Bar	7.24 Bar	3.31 Bar
Total Consumption of Pressure Zone (Summer)	715.6 m <sup>3</sup> /d	3562 m <sup>3</sup> /d	4296.07m <sup>3</sup> /d
Total Consumption of Pressure Zone (Winter)	606.2 m <sup>3</sup> /d	3239 m <sup>3</sup> /d	4137.12 m <sup>3</sup> /d



# Results (cont.)

Paarl Non-Revenue Water 1999 - 2011




# Results (cont.)

Drakenstein, Water, Water network, Water druk, Michele Street( F1360), Pressure

Mon 30 Jan 2012

[Back to site table](#)




Parameter	Min	Avg	Max
Pressure	298.469668	376.839627	428.70712

My City

# Results (cont.)


Average values, at 2 hourly intervals, between 2012-02-02 16:15:05 and 2012-02-09 16:15:05



Generated on 2012-02-09 @ 16:33:56 by ZEDNET, Copyright


# Results (cont.)

Paarl Water Demand 1959 - 2011




# Results (cont.)

## Paarl Water Demand 1989 to 2011



# Theoretical Savings in Volume

Volume (MI)



Actual Demand in MI  
Projected Demand @ 3.5% in MI  
Theoretical Savings in MI  
Total Savings 126993 MI

	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011
Actual Demand in MI	17891	13604	12292	12500	11531	10204	11040	11231	12391	11080	10609	10429
Projected Demand @ 3.5% in MI	18614	19265	19939	20637	21360	22107	22881	23682	24511	25368	26256	27175
Theoretical Savings in MI	723	5661	7647	8137	9829	11903	11841	12451	12120	14288	15647	16746

Year

# Theoretical Savings in Rands

Rand Value

R 70,000,000.00  
R 60,000,000.00  
R 50,000,000.00  
R 40,000,000.00  
R 30,000,000.00  
R 20,000,000.00  
R 10,000,000.00  
R 0.00

■ Projected Demand Rand Value  
■ Actual Demand Rand Value  
■ Theoretical Savings in Rands  
Total Savings = R 276,724,359.40

	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011
Projected Demand Rand Value	R 21,8	R 25,2	R 27,7	R 30,4	R 34,5	R 46,3	R 45,3	R 52,3	R 58,0	R 65,7	R 68,0	R 77,4
Actual Demand Rand Value	R 20,9	R 17,8	R 17,0	R 18,4	R 18,6	R 21,4	R 21,8	R 24,8	R 29,3	R 28,6	R 27,4	R 29,7
Theoretical Savings in Rands	R 848,	R 7,42	R 10,6	R 11,9	R 15,8	R 24,9	R 23,4	R 27,5	R 28,7	R 37,0	R 40,5	R 47,7

Year

# Way Forward

- Ongoing and Planned Projects
  - Upgrading and replacement of water network: Paarl, Wellington, Mbekweni, Gouda and Saron.
  - Upgrading of 450mm Bulk water supply pipeline at Saron
  - Construction of a WTP and Dam at Saron
  - Replacement of water pipeline from Withoogte Dam to Conmarine Reservoir
  - Construction and installation of a PRV stations and loggers at Wellington
  - Installation of water meters on unmetered industrial fire connections (Paarl & Wellington)
  - Upgrading of 350mm Ø pipeline between Bethel dam and Klipdam reservoir





# Challenges

- Funding
- Vandalism of infrastructure
- Buy in from council and technical management
- Scaricity of technical & trained staff & also retaining them
- Choosing and isolating the different pressure zones
- Keeping these pressure zones isolated







































SECUREX  
D 400 SABS EN124

KAMU DEN  
AKA











# Conclusions & Recommendations

- A thorough desktop study of the areas where pressure management is to be implemented must be undertaken
- Modelling of the water network to be pressure managed is crucial
- Zones with different pressure value must be identified and be properly demarcated
- Logging of existing pressures and flows of different demarcated zones is important to give a clear indication of the activities of the zone
- Size and positioning of PRV need to be correct to achieve effective and efficient pressure control
- Different PRV control modulations yield different results for different zones
- Continuous maintenance and monitoring of pressure zones is important to continue saving water



# Acknowledgements

- Mr. S Nkonyane (Senior Technician: Water Services ) who was/is in charge of the maintenance and management & installation of new pressure management systems.
- Drakenstein Municipality Council who approved, supported and financed the Pressure management part of the WDMS
- Raymond Vermeulen (4watersuppliers) for his advice and input in the installation and maintenance of the PRVs and Controllers



# Thank You!



**DRAKENSTEIN**  
MUNISIPALITEIT • MUNICIPALITY • U MASIPALA WASE